

Outdoor unit	RXF50D5V1B
Vnitřní jednotka	FTXF50D2V1B

Function		Heating season			
Chlazení	Ano	Average (mandatory)	Ano		
Vytápění	Ano	Warmer (if designated)	Ano		
		Colder (if designated)	Ne		

Položka	Symbol	Value	Jednotka	Položka	Symbol	Value	Jednotka
Design Load							
Chlazení / Average heating	Pdesignc	5.00	kW	Chlazení / Average heating	SEER	6.21	
Chlazení / Warmer heating	Pdesignh	4.60	kW	Chlazení / Warmer heating	SCOP / A	4.06	
Chlazení / Colder heating	Pdesignh	2.48	kW	Chlazení / Colder heating	SCOP / W	5.31	
	Pdesignh	2.12	kW		SCOP / C	-	

Deklarovaný chladicí výkon* pro chlazení při vnitřní teplotě 27(19) °C a venkovní teplotě Tj				Deklarovaný chladicí výkon* pro chlazení při vnitřní teplotě 27(19) °C a venkovní teplotě Tj			
Tj = 35 °C	Pdc	5.00	kW	Tj = 35 °C	EERd	3.33	
Tj = 30 °C	Pdc	3.69	kW	Tj = 30 °C	EERd	4.67	
Tj = 25 °C	Pdc	2.37	kW	Tj = 25 °C	EERd	6.92	
Tj = 20 °C	Pdc	2.12	kW	Tj = 20 °C	EERd	11.68	

Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh	4.07	kW	Tj = -7 °C	COPd	2.71	
Tj = 2 °C	Pdh	2.48	kW	Tj = 2 °C	COPd	3.98	
Tj = 7 °C	Pdh	1.60	kW	Tj = 7 °C	COPd	5.13	
Tj = 12 °C	Pdh	1.79	kW	Tj = 12 °C	COPd	6.91	
Tj = Bivalent temperature	Pdh	4.07	kW	Tj = Bivalent temperature	COPd	2.71	
Tj = operating limit	Pdh	4.07	kW	Tj = operating limit	COPd	2.06	

Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	2.48	kW	Tj = 2 °C	COPd	3.98	
Tj = 7 °C	Pdh	1.60	kW	Tj = 7 °C	COPd	5.13	
Tj = 12 °C	Pdh	1.79	kW	Tj = 12 °C	COPd	6.91	
Tj = Bivalent temperature	Pdh	2.48	kW	Tj = Bivalent temperature	COPd	3.98	
Tj = operating limit	Pdh	4.07	kW	Tj = operating limit	COPd	2.06	

Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7 °C	Pdh		kW	Tj = -7 °C	COPd		
Tj = 2 °C	Pdh		kW	Tj = 2 °C	COPd		
Tj = 7 °C	Pdh		kW	Tj = 7 °C	COPd		
Tj = 12 °C	Pdh		kW	Tj = 12 °C	COPd		
Tj = Bivalent temperature	Pdh		kW	Tj = Bivalent temperature	COPd		
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		
Tj = -15 °C	Pdh		kW	Tj = -15 °C	COPd		

Bivalent temperature				operating limit			
heating / Average	Tbiv	-7	°C	heating / Average	Tol	-15	°C
heating / Warmer	Tbiv	2	°C	heating / Warmer	Tol	-15	°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		°C

Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcyc		kW	for cooling	EErcyc		-
for heating	Pcych		kW	for heating	COPcyc		-
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-

Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode	Poff	0.001	kW	Chlazení	QCE	282	kWh/a
Standby mode	Psb	0.001	kW	heating / Average	QHE	1,585	kWh/a
Thermostat-off mode	PTO	0	kW	heating / Warmer	QHE	654	kWh/a
Crankcase heater mode	PCK	0	kW	heating / Colder	QHE		kWh/a

Capacity control				Other items			
fixed	N			Sound power level (indoor/outdoor)	LWA	59.0 / 61.0	db(A)
staged	N			Global warming potential	GWP	675	kgCO ₂ eq.
variable	N			Rated air flow (indoor/outdoor)	-	16.8 / 43.2	m ³ /min

Contact details for obtaining more information	Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium						
--	---	--	--	--	--	--	--

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.